Material Submittal

dar

Date: 11-Nov-20

Material Submittal No.: S19091-DIB-NASJV-PK1-MAT-S-0119-00

Project no. & Title: S19091-DESIGN AND EXECUTION OF KING SALMAN AIR BASE FACILITIES IN DYRAB (CENTRAL SECTOR)

Client:	Construction Supervision Consultant :	Contractor:
وزارة الدفاع MINISTRY OF DEFENSE	dar	NAS JOINT VENTURE

1. Material description (one item only on this form) :

STEEL REINFORCEMENT BAR, UNCOATED (BLACK) - WATANIA STEEL

Area of application : VARIOUS

Drawing ref. : B.O.Q. Item. no.:

Specification Ref. : 03200 Standards:

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. Manufacturer / supplier

Company Name : WATANIA STEEL FACTORY CORP.

Address : RIYADH, K.S.A.

Local agent :

3. Delivery :

Country of origin : K.S.A.

Availability: ◉ Locally Manufactured ○ Overseas

Delivery :	Ex-works/ total duration	[ ]	[ ]
	Estimated time of arrival on site	[ ]	
Program :	Date material required on site	[ ]	
	Latest date for order	[ ]	

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Submitted by : NASJV - Engineer Signature: 11 Nov 2020

4. Construction Supervisor's Representative comments: M.Q

Refer to the attached comments on 01(A4) sheet.

- ☐ Approved
- ■ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected
- ☐ Sample required
- ☐ Tests required
- ☐ Additional information required
- ☐ Manufacturer's guarantee required

Name :

Signature: Date: 11-11-2020

5. Employer's representative comments

- ☐ Approved
- ☐ Approved as noted
- ☐ Revise and resubmit
- ☐ Rejected

Name :

Signature: Date:

Approval shall not relieve Contractor of his liabilities under the Contract or constitute authorization of any change to Contract Documents.

Submittal: S19091-DIB-NASJV-PK1-MAT-S-0119-00
Material: STEEL REINFORCEMENT BAR, UNCOATED (BLACK). "WATANIA STEEL - RIYADH"
Specification: 03200.2.01.B
Code: *Approved as Noted*
Comment:

1. *As per provided documents, the reinforcing steel bars non-wieldable Grade 60 ASTM A 615/A615M-20 manufactured by **WATANIA** steel factory is approved as noted, unless otherwise indicated on Drawings.*
2. *Periodic/frequency of quality tests of reinforcing steel bars shall be established.*
3. *Prior to use the subject steel bars in permanent work at site ,samples of all sizes of steel bars for concrete reinforcement shall be collected for full quality test as per the ASTM 615/615M-20 requirements.*
4. *The manufacturer to submit samples of each size of steel bars.*
5. *The steel bars shall be properly separated and tagged with the manufacturer's heat or test identification number.*
6. *The manufacturer shall identity the symbols of their marking system on steel bars.*