pace المكتب العربي | AECOM | شمول Shomoul | Nesma & Partners نسما وشركاهم | SITE 03-01

Transmittal for Drawings, Document Samples, etc. (TR)

Project Title	The Avenues Riyadh - Phase 1 Mall		
Construction Supervision Consultant	PACE	**Contract No.**	
Contractor	Nesma & Partners Co.	**PMC**	AECOM
Revision	00	**TR Number**	MD-AVR1-CIV-061
		Date	16 / 06 / 2022
To	PACE		

We are sending herewith/under separate cover, the drawings/documents/samples listed below.
We certify that the item listed below is in strict accordance with the contract documents.

Qty.	Draw., Spec., or BOQ. Ref.	Item Seq. No.	Description	+ Type	Submitted for	Action
	03 30 00		Steel Rebar Gr. 60	MD	Approval	B
			For Cast-In-Place Concrete			
			Brand : Watania Steel			
			Country of Origin : Saudi Arabia			
			New Industrial City, New Al-Kharj Road P.O. Box 355885, Riyadh 11383			

Previous Revision Status						
	Rev. No.					
	Action Code:					

*Contractor to submit one item only per transmittal.

Submitted for: 1 - Approval 2 - Your Information

Action: A - Approved; B - Approved as Noted; BR - Approved as Noted, Resubmit; C - Not Approved; DR - Information Required; D - For Information Only

+ Type: SD - Shop Drawings; TS - Test Report; CT - Certificates; MC - Mock-up; MTS - Method Statement; SM - Sample; RM - Re-Measurement; OT - Other; MD - Manufacturer's Data; ITP - Inspection & Test Plan; GT - Guarantee; VT - Variation; SC - Structural Calculations; AB - As Built; IFC - IFC Drawings

Sub-Contractor	name and signature	date ____ / ____ / ____
Contractor's PM.	name and signature	date 16 / 06 / 2022

Copies to: Employer ☐ Project Director ☐ Contractor ☐ PMC ☐

Construction Supervision Consultant's approval/comments: Code B - Approved as Noted

1- Alwatania steel is approved for cast in place concrete 2- Necessary tests must be carried out on all rebar diameters.

3- Full compliance with all related contract documents.

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions selecting fabrication processes and techniques of the construction; coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

Construction Supervision Consultant	name and signature	date 20 / 06 / 2022
PMC Representative	name and signature	date ____ / ____ / ____
Employer Representative	name and signature Required ☐ Y ☐ N	date ____ / ____ / ____

Distribution: Employer ☐ Project Director ☐ Contractor ☐ PMC ☐