Supervision Consultant:	The Employer:	The Contractor:
ATKINS	مدينة محمد بن سلمان Mohammed Bin Salman City Nonprofit غير الربحية	ALEC

Project: 5218794-MBS City Non-Profit - ilmi Main Works

Material Submittal

P-0001-PH01-D01-01A001-ALEC-MAT-STR-000001

Rev. No.00

Originator of Submittal : **Alec** *Date:* **5/4/2024**

Authorised Sign : *Reqd. By:*

Material Detail Reinforcment		***List of Enclosure*** (Tick the Related Box)
Item Description	**Reinforcement Bars**	
Specs. Reference	***032000***	☑ Vendor's Technical Literature
BOQ Reference		☑ Compliance Statement
Drwg. Reference		☐ Previous Test Results
Material Specified		☑ Copy of the Related Specs.
Material Proposed	***Reinforcement Bars***	☐ Samples with Sample Tag
Manufacturer / Supplier	***WATANIA STEEL / Riyadh Development company***	☑ List of Previous Projects Done
Remarks		☐ Others (Specify):

Contractor Statement: We certify that the material submitted herewith has been reviewed in details and is in compliance with the contract drawings and specifications except as otherwise stated hereabove.

Contractor Sign: *Date:* ***5/4/2024***

ATKINS Received Sign: *Date:*

Ref.No **5218794/R11-**

ATKINS Engineer's Comments:

1. Please use the standard form for compliance statement.
2. Submit sample along with the sample tag for future reference and to be kept on the designated sample room.
3. Submit sample/specimen for all proposed materials and to be tested by the approved ITL. Test reports to be submitted for review and final approval of the materials.
4. Note: All related test report must be certified from the local authority with no older than a month to be attach every delivery

Reviewed By: Karol Sarmiento *Date:* April 15, 2024

ATKINS Resident Engineer's Comments:

- ☐ Code A - Approved
- ☐ Code B - Approved with Comments
- ☐ Code C - Revise and Resubmit
- ☐ Code D - Rejected
- ☐ Code E - For Information

ATKINS RE Sign: AtkinsRéalis Mohammed Musthafa Resident Engineer *Date:*

Ref.No **5218794/R10-**

Contractor Received Sign: *Date:*

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the contract requirement and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents.